



WATER METER:

BRONZE 0-30 GPM POSITIVE DISPLACEMENT WATER FLOW METER W/ 1 GAL/COUNT CONTACTING HEAD, CARLON MODEL JSJ075

NOTE: ALL NEW PIPING COMPONENTS TO BE LINE SIZE TO MATCH EXISTING MAKEUP PIPING EXCEPT PRESSURE GAUGE VALVES TO BE 1/4". ALL OTHER COMPONENTS PER UM STD SPECS. PRESSURE GAUGES TO BE 0-100 PSIG.

CLOSED SYSTEM MAKEUP DETAIL

NO SCALE

D 15189 02 04 08.dgn

REFERENCED DETAILS/SCHEDULES:

ADDITIONAL INFORMATION:

MODULES: 1



ARCHITECTURE & ENGINEERING
326 East Hoover, Mail Stop B
Ann Arbor, MI 48109-1002
Phone: 734-764-3414
Fax: 734-936-3334

**Closed System
Makeup Detail**

DIVISION: 15
SECTION: 15515
FILE: D 15189 02 04 08
ISSUE DATE: 04/15/08