



**NOTES**

- ① CONNECT TO SIDE OF MAIN (AVOID TOP AND BOTTOM). PROVIDE ANTI-THERMO SIPHON LOOP. CONNECT TO NEW EXPANSION TANK.
- ② INSULATE PER SPECIFICATIONS.
- ③ PROVIDE ROOM FOR SCREEN REMOVAL.

**COALESCING SEPARATOR TO EXPANSION TANK DETAIL**

NO SCALE

D 15515 007 05 04.dgn

REFERENCED DETAILS/SCHEDULES:  
XXXX S 15515 001 05 04

ADDITIONAL INFORMATION:

MODULES: X

THE UNIVERSITY OF MICHIGAN  
PLANT EXTENSION  
ARCHITECTURE, ENGINEERING & CONSTRUCTION  
ARCHITECTURAL AND  
ENGINEERING SERVICES  
326 EAST HOOVER STREET  
ANN ARBOR, MI 48109-1002

**Coalescing Separator to Expansion Tank Detail**

DIVISION: 15  
SECTION: 15515  
FILE: D 15515 007 05 04.dgn  
ISSUE DATE: 05/28/04